



A P P R O V A L S ®

Certificate of Conformity

Certificate No.: SAA-192378-EA

Certificate Holder: Wenzhou Tongou Electrical Co., Ltd
Paidong Industrial, Liushi Town,
Wenzhou City,
P.R. China

Class Description: Residual Current Device
Product Description: RCBO
Trade Name: TONGOU
Model No.: TOBN1-32
Markings: Un=230/240V~(1P+N), 50/60Hz;
In=6, 10, 16, 20, 25, 32A B & C-type
IΔn=0.01, 0.03A, type A & AC
Icn=Ics=6000A
T
Standard: AS/NZS 61009.1:2015
Conditions: Nil

Approval Mark: RCM and SAA-192378-EA

Date First Registered: 10 September 2019
Date of Expiry: 10 September 2024

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 11-09-19 192378/1a
Standard amended